

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Recessed luminaires
Name and address of the Applicant Nom et adresse du demandeur	REGGIANI S.P.A. ILLUMINAZIONE Viale Monza 16 20845 Sovico (MB) Italy
Name and address of the manufacturer Nom et adresse du fabricant	REGGIANI S.P.A. ILLUMINAZIONE Viale Monza 16 20845 Sovico (MB) Italy
Name and address of the factory Nom et adresse de l'usine	REGGIANI S.P.A. ILLUMINAZIONE Viale Monza 16 20845 Sovico (MB) Italy
Rating and principal characteristics Valeurs nominales et caractéristiques principales	1x30 W Ceramic Cob LEDs, 850 mA, 39 Vdc max, Class III, IP20 Refer to ANNEX 1 for the entire list of rating covered by the certificate
Trademark (if any) Marque de fabrique (si elle existe)	Reggiani S.p.A.
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	cod. X.0F27A
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	Refer to ANNEX 1 for the entire list of models covered by the certificate
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	60598-1(ed.8) 60598-2-2(ed.3)
National differences / Comments Les différences nationales / Commentaires	EU Group Differences
As shown in the test report Ref. No. which forms part of this certificate Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat	3504166.71

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands



Date: 2015-11-04

Signature: M.Triulzi

Triulzi Massimo

Code	Insulation class	Colour temperature	IP degree	t _a
cod x.0F2yz	III	2700 K HW 3000 K HQ 3000 K WW 4000 K NN	IP20	25 °C

LEGEND

x	Type of luminaire	X = without the controlgear.
y	Type of rating	3 = 13 W 350 mA 39 V max 5 = 22 W 600 mA 39 V max 6 = 25 W 700 mA 39 V max 7 = 30 W 850 mA 39 V max
z	Type of optical reflector	A = with optical reflector cod 0.35049.0000 satin very narrow beams B = with optical reflector cod 0.35050.0000 very narrow beams C = with optical reflector cod 0.35051.0000 narrow beams D = with optical reflector cod 0.35052.0000 medium beams E = with optical reflector cod 0.35053.0000 wide beams F = with optical reflector cod 0.35054.0000 Mira G = with optical reflector cod 0.35055.0000 wide beams H = with optical reflector cod 0.35059.0000 Wall Washer beams K = without optical reflector